



**QUANTITY & SIZE:**  
 (1) 4'-2" X 4'-0" MARK

**WALL CONSTRUCTION:**  
 Steel  Masonry  Other

**MATERIAL & FINISH:**  
 CURTAIN - GALVANIZED STEEL, GALVANEX FINISH CORNELL GRAY  
 BOTTOM BAR - PLAN STEEL, POWDER COATED CORNELL GRAY  
 GUIDES - PLAN STEEL, POWDER COATED CORNELL GRAY  
 HOOD - GALVANIZED STEEL, GALVANEX FINISH CORNELL GRAY  
 PLAN STEEL - POWDER COATED CORNELL GRAY

**LOCKING:**  
 Slidebolt with hasp for padlocking located at both jambs.  
 Padlocks by others, #1/4" maximum strok.

Lacking is operable from the COIL SIDE only.

NOTE: Location of fuselinks / thermal sensors as shown, is simply a visual representation. Fuselinks / thermal sensors should be properly installed per NFPA bulletin 80 and in accordance with the authority having jurisdiction.

DRAWN BY: WEB  
 DATE: 05/26/11



AGENT NO: Web999136 001 A

07/18/2011  
 BSE\_UL9R

PUSH-UP OPERATED ROLLING COUNTER FIRE DOOR  
 ROLLING COUNTER FIRE DOOR